



EXCHANGER SIZE * - BAFFLE SPACING	DIMENSIONS											
	A		B		C		D		N1		N2	
	inches	mm	inches	mm	inches	mm	inches	mm	inches	mm	inches	mm
W-62-4*-4	35 5/8	905	16	406	7	178	25	635	2	51	2	51
W-63-4*-4	47 5/8	1210	28	711	19	483	37	940	2	51	2	51
W-64-4*-4	59 5/8	1514	40	1016	31	787	49	1245	2	51	2	51
W-65-4*-4	71 5/8	1819	52	1321	43	1092	61	1549	2	51	2	51
W-66-4*-4	83 5/8	2124	64	1626	55	1397	73	1854	2	51	2	51
W-67-4*-4	95 5/8	2429	76	1930	67	1702	85	2159	2	51	2	51
W-68-4*-4	107 5/8	2734	88	2235	79	2007	97	2464	2	51	2	51
W-69-4*-4	119 5/8	3038	100	2540	91	2311	109	2769	2	51	2	51
W-610-4*-4	131 5/8	3343	112	2845	103	2616	121	3073	2	51	2	51
W-611-4*-4	143 5/8	3648	124	3150	115	2921	133	3378	2	51	2	51
W-612-4*-4	155 5/8	3953	136	3454	127	3226	145	3683	2	51	2	51

NOZZLE SCHEDULE				
SERVICE	MARK	SHELL SIDE	MARK	TUBE SIDE
INLET	N1	AS PER TABLE	N5	1 1/2 (38) FLG
OUTLET	N2	AS PER TABLE	N6	1 1/2 (38) FLG
DRAIN	N3	1/2 (13) NPT	N7	1/2 (13) NPT
VENT	N4	3/4 (19) NPT		

NOTES: 1. SUPPORTS SUPPLIED ONLY IF SPECIFIED ON ORDER.
 2. NOZZLE SIZES SHOWN ARE RECOMMENDED FOR MAXIMUM EXCHANGER LIFE.
 3. FABRICATED TO ASME CODE SECTION VIII DIVISION 1 AND LATEST ADDENDA.
 4. DRAWING IS NOT TO SCALE.
 5. ALL DIMN'S ±1/8 (3) UNLESS OTHERWISE SHOWN.

DESIGN CONDITIONS				
	SHELL		TUBES	
DESIGN PRESSURE	150 PSIG	1034 KP _a	150 PSIG	1034 KP _a
DESIGN TEMPERATURE	375 °F	191 °C	375 °F	191 °C
MIN. DESIGN METAL TEMP.	35 °F	1.7 °C	35 °F	1.7 °C
HYDRO. TEST PRESSURE	225 PSIG	1551 KP _a	225 PSIG	1551 KP _a
CONTENTS	WATER		WATER	

CUSTOMER:
 LOCATION:
 ENGINEER:
 ORDER No.:
 PROJECT/JOB:
 LOCATION:
 TAG: (QUOTE #)

TITLE	A R M S T R O N G				NUMBER	REV.
G.A. 150 LB. W SERIES HEAT EXCHANGERS	TORONTO - CANADA	MONTREAL - CANADA	BUFFALO - N. Y.	COLCHESTER - U.K.	W-6-4P-4-(2)	
DATE: 12 / 01 / 94 BY: D.C.R.	TEL : (416) 755-2291	TEL : (514) 421-2424	TEL: (716) 693-8813	TEL: (44) 120-657-9491		