



EXCHANGER SIZE	DIMENSIONS								NOZZLE SCHEDULE		
	"A"		"B"		"C"		"D"		(N1) INLET	6" FLG (152)	
	Inches	mm	Inches	mm	Inches	mm	Inches	mm	(N2) OUTLET	6" FLG (152)	
THW-1436-2-2	49 -3/8	1254	35-3/4	908	38	965	24-1/2	622	(N3) DRAIN	1/2" NPT (13)	
THW-1442-2-2	55 -3/8	1407	41-3/4	1060	44	1118	30-1/2	775	COLLAR ASSEMBLY		
THW-1448-2-2	61 -3/8	1559	47-3/4	1213	50	1270	36-1/2	927		STANDARD	OVS. FOR STONE LINING
THW-1454-2-2	67 -3/8	1711	53-3/4	1365	56	1422	42-1/2	1080	"E"	14" (356)	16" (406)
THW-1460-2-2	73 -3/8	1864	59-3/4	1518	62	1575	48-1/2	1232	"F"	10-1/2" (267)	12" (305)
THW-1466-2-2	79 -3/8	2016	65-3/4	1670	68	1727	54-1/2	1384	DESIGN CONDITIONS		
THW-1472-2-2	85 -3/8	2169	71-3/4	1822	74	1880	60-1/2	1537		TUBES	
THW-1478-2-2	91 -3/8	2321	77-3/4	1975	80	2032	66-1/2	1689	DESIGN PRESSURE	150 PSIG	1034 KPa
THW-1484-2-2	97 -3/8	2473	83-3/4	2127	86	2184	72-1/2	1842	DESIGN TEMPERATURE	375 F	191 C
THW-1490-2-2	103-3/8	2626	89-3/4	2280	92	2337	78-1/2	1994	M.D.M.T.	40 F	4.4 C
THW-1496-2-2	109-3/8	2778	95-3/4	2432	98	2489	84-1/2	2146	HYD. TEST PRESSURE	300 PSIG	2068 KPa
THW-14102-2-2	115-3/8	2931	101-3/4	2584	104	2642	90-1/2	2299	NOTES:		
THW-14108-2-2	121-3/8	3083	107-3/4	2737	110	2794	96-1/2	2451	1. COLLAR ASSEMBLY SUPPLIED SEPARATELY.		
THW-14114-2-2	127-3/8	3235	113-3/4	2889	116	2946	102-1/2	2604	2. FABRICATED TO ASME CODE SECTION VIII DIVISION 1 AND LATEST ADDENDA.		
THW-14120-2-2	133-3/8	3388	119-3/4	3042	122	3099	108-1/2	2756	3. DRAWING IS NOT TO SCALE.		
THW-14126-2-2	139-3/8	3540	125-3/4	3194	128	3251	114-1/2	2908	4. ALL DIMN'S 1/8 (3) UNLESS OTHERWISE SHOWN.		
THW-14132-2-2	145-3/8	3693	131-3/4	3346	134	3404	120-1/2	3061	5. DIMENSIONS SHOWN AS: In.(mm)		
THW-14138-2-2	151-3/8	3845	137-3/4	3499	140	3556	126-1/2	3213	CUSTOMER:		
THW-14144-2-2	157-3/8	3997	143-3/4	3651	146	3708	132-1/2	3366	LOCATION:		
THW-14150-2-2	163-3/8	4150	149-3/4	3804	152	3861	138-1/2	3518	ENGINEER :		
THW-14156-2-2	169-3/8	4302	155-3/4	3956	158	4013	144-1/2	3670	ORDER No.:		
THW-14162-2-2	175-3/8	4455	161-3/4	4108	164	4166	150-1/2	3823	PROJECT/JOB:		
									LOCATION:		
									TAG:		
									QUOTE #		